



Product Service

CERTIFICATE

No. Z2 125865 0001 Rev. 00

Holder of Certificate: GruppoSTG Fabbrica S.r.l.

Via Paleocapa 19
24122 Bergamo
ITALY

Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262413401-00

Valid until: 2028-12-19

Date, 2024-05-13

(Zhulin Zhang)



CERTIFICATE

No. Z2 125865 0001 Rev. 00

Model(s):

VE672PV-xxxW (xxx=545-580, in steps of 5)
VE672PVB-xxxW (xxx=545-580, in steps of 5)
VE660PV-xxxW (xxx=455-480, in steps of 5)
VE660PVB-xxxW (xxx=455-480, in steps of 5)
VE654PV-xxxW (xxx=405-430, in steps of 5)
VE654PVB-xxxW (xxx=405-430, in steps of 5)
VE654PVTB-xxxW (xxx=405-430, in steps of 5)
VE672PV-xxxW (xxx=535-550, in steps of 5)
VE672PVB-xxxW (xxx=535-550, in steps of 5)
VE660PV-xxxW (xxx=445-460, in steps of 5)
VE660PVB-xxxW (xxx=445-460, in steps of 5)
VE654PV-xxxW (xxx=400-415, in steps of 5)
VE654PVB-xxxW (xxx=400-415, in steps of 5)
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC or 1000 V DC
Fire Safety Class:	Class C according to UL790.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China

Tested according to:

IEC 61730-1:2016
IEC 61730-2:2016
IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021